



## HeatMaster TC - DHW PRODUCTION WITH AN EXTRA HOT WATER TANK

In some buildings, where a lot of hot water is used in a short period of time (large needs and short cycles) it is possible to use an extra hot water tank. This increases peak flows with the amount of storage of water in the tank. The loading pump can be controlled by the adjusting thermostat. The boiler temperature must be higher than the tank temperature. This solution is suggested when a solution based on a higher powered boiler is not possible or desirable.

